

Where to get your water tested

Private Well Test Kits

The kits are **\$4 each** and can be purchased at any of the locations listed below. The test kit contains two bottles: one to test for chemicals and one to test for bacteria. Instructions are included with each bottle and should be followed precisely. Drop off water samples at any of the same locations. Additional bottles are \$2 each.

New Castle County

Limestone Professional Building

2055 Limestone Road, Suite 100
Wilmington, DE 19808
(302) 995-8650

Middletown Health Unit

214 N. Broad Street
Middletown, DE 19709
(302) 378-5200

Kent County

Thomas Collins Building

540 S. Dupont Highway, Suite 5
Dover, DE 19901
(302) 744-1220

Division of Public Health Laboratory

30 Sunnyside Road
Smyrna, DE 19977
(302) 223-1520

Sussex County

Georgetown State Service Center

544 S. Bedford Street
Georgetown, DE 19947
(302) 856-5496

Did you know?

- The Office of Drinking Water monitors approximately 520 public water systems throughout Delaware.
- Delaware residents use approximately 91 million gallons of public water each day.
- About 18% of Delaware residents own a private well in which the water quality is not regulated by either the federal or state government.
- The Office of Drinking Water recommends that owners of private wells have their water tested annually for chemical and bacteriological contaminants.

For More Information Contact:
Office of Drinking Water
Blue Hen Corporate Center
655 Bay Road, Suite 203
Dover, DE 19901
(302) 741-8630
FAX: (302) 741-8631



**DELAWARE HEALTH
AND SOCIAL SERVICES**
Division of Public Health

Delaware Division of Public Health **OFFICE OF DRINKING WATER**



A Guide to Help Interpret Your Drinking Water Results

Guide to Understanding Your Drinking Water Results

Analyte	Description	Parts per million (ppm) = mg/L milligrams per liter Regulated analytes: maximum contaminant level (MCL) value. Unregulated analytes: secondary standard (SS) value.
Alkalinity	Alkalinity is a measure of the buffering capacity of water. Know the alkalinity of water when installing treatment for other water quality parameters such as pH.	There is no recommended level for alkalinity
Chloride (Cl)	Chloride may adversely affect the taste, odor or color of drinking water, but does not pose any known health risk. At 250 ppm, water could taste foul.	(SS) 250 ppm . Note: High chlorides may also indicate salt water intrusion or a failing septic system.
Fluoride (F)	Fluoride can naturally occur in groundwater. All municipalities in Delaware are required to add fluoride to the drinking water for added dental benefits.	(MCL) 2.0 ppm Delaware's optimum range for fluoride is (0.8 – 1.2 ppm). Fluoride should not exceed 2.0 ppm .
Hardness	Calcium and magnesium are two minerals which make water hard. Water hardness is measured either in grains per gallon (gpg) or as calcium hardness in ppm. One grain is equal to 17 ppm.	(SS) The degrees of hardness range from soft to hard: <ul style="list-style-type: none"> • < (less than) 60 ppm: soft • 60-120 ppm: moderately hard • > (greater than) 120 ppm: extremely hard
Iron (Fe)	Iron is the earth's fourth most abundant element and is found in nearly all water supplies. Iron may adversely affect the aesthetic quality of drinking water by taste, odor or color. However, iron does not pose any known health effects.	(SS) 0.3 ppm Above this level, iron may cause staining in household appliances, fixtures and laundry. At very low levels, treatment may not be necessary.
Nitrate (NO ₃)	Nitrate occurs naturally in some ground water, as a result of fertilizer use or from a failing septic system. Since nitrates reduce the oxygen carrying capacity in the blood, they are harmful to unborn children and infants less than six months of age. In infants, the lack of oxygen causes the skin to appear blue or gray, a condition known as Blue Baby Syndrome.	(MCL) 10 ppm (Acute Contaminant) If the level is 10 ppm or less means that your drinking water meets drinking water standards.
Nitrite (NO ₂)	Nitrites (NO ₂) are not stable in drinking water and can quickly change to Nitrates (NO ₃). The sources are the same and they both can cause Blue Baby Syndrome. To protect against the risk of adverse effects, the United States Environmental Protection Agency (EPA) has set the drinking water standard at 1 ppm.	(MCL) 1 ppm (Acute Contaminant) If the level is 1 ppm or less means that your water meets drinking water standards.
pH	pH is a numerical expression indicating whether your water is acidic or basic. High pH levels are undesirable since they may give the water a bitter taste. Low pH levels may leach copper and lead from your metal pipes.	(SS) 6.5 – 8.5 (Range of where environmental and aesthetic benefits can be achieved) Scale of 0 –14 0 = highly acidic; 7 = neutral; 14 = highly basic
Sodium (Na)	The EPA suggests a guidance level for sodium of 20 ppm in drinking water for those on severely salt-restricted diets. A level of 200 ppm or less is suggested for unrestricted diets.	(SS) <ul style="list-style-type: none"> • < (less than) 20 ppm for salt-restricted diets • 200 ppm or less for unrestricted diets
Sulfate (SO ₄)	Sulfates are a combination of sulfur and oxygen that can be released into groundwater from soil or rock formations.	(SS) 250 ppm Higher levels may cause diarrhea.